

km200.0									
dhwCircuits									
dhw1									
holidayMode									
temperatureLevels									
high	dhwCircuits.dhw1.temperatureLevels.high	state	level.temperature		44 °C				
low	dhwCircuits.dhw1.temperatureLevels.low	state	level.temperature		40 °C				
off	dhwCircuits.dhw1.temperatureLevels.off	state	value.temperature		0 °C				
actualTemp	dhwCircuits.dhw1.actualTemp	state	value.temperature		47.9 °C				
charge	dhwCircuits.dhw1.charge	state	level		stop(0)				
chargeDuration	dhwCircuits.dhw1.chargeDuration	state	level		00:45 mins				
currentSetpoint	dhwCircuits.dhw1.currentSetpoint	state	value.temperature		0 °C				
operationMode	dhwCircuits.dhw1.operationMode	state	level		ownprogram(3)				
singleChargeSetpoint	dhwCircuits.dhw1.singleChargeSetpoint	state	level.temperature		64 °C				
status	dhwCircuits.dhw1.status	state	value		ACTIVE(1)				
waterFlow	dhwCircuits.dhw1.waterFlow	state	value		0 l/min				
workingTime	dhwCircuits.dhw1.workingTime	state	value		00:00 mins				

km200.0									
dhwCircuits									
heatingCircuits									
hc1									
holidayMode									
activated	heatingCircuits.hc1.holidayMode.activated	state	value		(0)				
temperatureLevels									
comfort2	heatingCircuits.hc1.temperatureLevels.comfort2	state	level.temperature		21.5 °C				
eco	heatingCircuits.hc1.temperatureLevels.eco	state	level.temperature		21 °C				
activeSwitchProgram	heatingCircuits.hc1.activeSwitchProgram	state	level		B(1)				
actualSupplyTemperature	heatingCircuits.hc1.actualSupplyTemperature	state	value.temperature		31.5 °C				
currentRoomSetpoint	heatingCircuits.hc1.currentRoomSetpoint	state	value.temperature		21 °C				
manualRoomSetpoint	heatingCircuits.hc1.manualRoomSetpoint	state	level.temperature		21 °C				
operationMode	heatingCircuits.hc1.operationMode	state	level		auto(0)				
pumpModulation	heatingCircuits.hc1.pumpModulation	state	value		100 %				
roomTemperature	heatingCircuits.hc1.roomTemperature	state	value.temperature		21.1 °C				
status	heatingCircuits.hc1.status	state	value		ACTIVE(1)				
supplyTemperatureSetpoint	heatingCircuits.hc1.supplyTemperatureSetpoint	state	value.temperature		31 °C				
switchProgramMode	heatingCircuits.hc1.switchProgramMode	state	level		levels(0)				
temperatureRoomSetpoint	heatingCircuits.hc1.temperatureRoomSetpoint	state	level.temperature		21 °C				
temporaryRoomSetpoint	heatingCircuits.hc1.temporaryRoomSetpoint	state	level.temperature		-1 °C				

km200.0									
dhwCircuits									
heatingCircuits									
hc1									
system									
appliance									
workingTime									
CHpumpModulation	system.appliance.CHpumpModulation	state	value		5 %				
ChimneySweeper	system.appliance.ChimneySweeper	state	value		0				
actualPower	system.appliance.actualPower	state	value		100 %				
actualSupplyTemperature	system.appliance.actualSupplyTemperature	state	value.temperature		26.8 °C				
fanSpeed_setpoint	system.appliance.fanSpeed_setpoint	state	value		0 rpm				
flameCurrent	system.appliance.flameCurrent	state	value		0 µA				
nominalBurnerLoad	system.appliance.nominalBurnerLoad	state	value		24 kW				
numberOfStarts	system.appliance.numberOfStarts	state	value		0				
powerSetpoint	system.appliance.powerSetpoint	state	value		255 %				
systemPressure	system.appliance.systemPressure	state	value		0 bar				
heatSources									
hs1									
fuel									
caloricValue	system.heatSources.hs1.fuel.caloricValue	state	level		11.5 kWh				
density	system.heatSources.hs1.fuel.density	state	level		0.82 kg/l				
actualModulation	system.heatSources.hs1.actualModulation	state	value		100 %				
actualPower	system.heatSources.hs1.actualPower	state	value		24 kW				
energyReservoir	system.heatSources.hs1.energyReservoir	state	level		0 kWh				
fuelConsumptCorrFactor	system.heatSources.hs1.fuelConsumptCorrFactor	state	level		1				
nominalFuelConsumption	system.heatSources.hs1.nominalFuelConsumption	state	level		1.8 l/h				
reservoirAlert	system.heatSources.hs1.reservoirAlert	state	level		0 kWh				

km200.0									
dhwCircuits									
heatingCircuits									
hc1									
system									
appliance									
heatSources									
sensors									
temperatures									
outdoor_t1	system.sensors.temperatures.outdoor_t1	state	value.temperature		-1.4 °C				
return	system.sensors.temperatures.return	state	value.temperature		26.8 °C				
supply_t1	system.sensors.temperatures.supply_t1	state	value.temperature		26.8 °C				
supply_t1_setpoint	system.sensors.temperatures.supply_t1_setpoint	state	value.temperature		30 °C				
switch	system.sensors.temperatures.switch	state	value.temperature		26.7 °C				
brand	system.brand	state	value		Buderus(3)				
bus	system.bus	state	value		EMS2_0(2)				
healthStatus	system.healthStatus	state	value		ok(2)				
info	system.info	state	value		[{ Tok: '8', Id: '172', Ver: '01' }				
minOutdoorTemp	system.minOutdoorTemp	state	level.temperature		-20 °C				
systemType	system.systemType	state	value		NSC_ICOM_GATEWAY(0)				
notifications	notifications	state	value		[]				